

Product Information Bulletin 223

GREENGUARD Certification Listing – Insulspan SIP System

Product Information Bulletin

BULLETIN NO.	223
ISSUED:	March 26, 2019
REPLACES:	August 14, 2015

GREENGUARD Certification Program - Insulspan SIP System

(Two pages attached)



As part of our commitment to quality and ongoing sustainability initiatives, Insulspan[®] maintains GREENGUARD Certification for the Insulspan SIP (Structural Insulating Panel) System. The Insulspan SIP System is an energy efficient building system consisting of a PlastiSpan[®] or EnerSpan[®] insulation core with oriented strand board (OSB) structurally laminated to the interior and exterior faces.

GREENGUARD certification is provided by UL Environment, an independent global safety science organization using their processes and procedures in accordance with established environment and safety standards.

The GREENGUARD Certification mark on the Insulspan SIP System gives assurance that products designed for use in indoor spaces meet strict chemical emissions limits, which contribute to the creation of healthier interiors. Achieving GREENGUARD Certification gives credence to Plasti-Fab sustainability claims, backing them with empirical scientific data from an unbiased, third-party organization.

The GREENGUARD standard achieved by the Insulspan SIP System includes health based criteria for additional chemicals and also requires lower total VOC emissions levels to ensure that products are acceptable for use in environments such as schools and healthcare facilities.

The attached GREENGUARD Gold Certificate of Compliance from UL Environment provides additional information regarding certification criteria used to establish the listing for the Insulspan SIP System.

GREENGUARD certified product listings can be found at: https://spot.ul.com/main-app/products/detail/5ad1ebc855b0e82d946a7171?page_type=Products%20Catalog

CERTIFICATE OF COMPLIANCE



Plasti-Fab Ltd.

Insulspan® Structural Insulating Panels

70086-420

Certificate Number

08/06/2015 - 04/23/2019

Certificate Period

Certified

Status

UL 2818 - 2013 Gold Standard for Chemical Emissions for Building Materials, Finishes and Furnishings

Wall finishes are determined compliant in accordance with California Department of Public Health (CDPH) Standard Method V1.2-2017 using a Classroom Environment with an air change of 0.82 hr^{-1} and a loading of 94.60 m^2 .

Product tested in accordance with UL 2821 test method to show compliance to emission limits on UL 2818. Section 7.1 and 7.2.



UL investigated representative samples of the identified Product(s) to the identified Standard(s) or other requirements in accordance with the agreements and any applicable program service terms in place between UL and the Certificate Holder (collectively "Agreement"). The Certificate Holder is authorized to use the UL Mark for the identified Product(s) manufactured at the production site(s) covered by the UL Test Report, in accordance with the terms of the Agreement. This Certificate is valid for the identified dates unless there is non-compliance with the Agreement.

GREENGUARD Gold Certification Criteria for Building Products and Interior Finishes

Criteria	CAS Number	Maximum Allowable Predicted Concentration	Units
TVOC ^(A)	-	0.22	mg/m ³
Formaldehyde	50-00-0	9 (7.3 ppb)	µg/m ³
Total Aldehydes ^(B)	-	0.043	ppm
4-Phenylcyclohexene	4994-16-5	6.5	µg/m ³
Particle Matter less than 10 µm ^(C)	-	20	µg/m ³
1-Methyl-2-pyrrolidinone ^(D)	872-50-4	160	µg/m ³
Individual VOCs ^(E)	-	1/2 CREL or 1/100th TLV	-

- (A) Defined to be the total response of measured VOCs falling within the C₆ – C₁₆ range, with responses calibrated to a toluene surrogate. Maximum allowable predicted TVOC concentrations for GREENGUARD Gold (0.22 mg/m³) fall in the range of 0.5 mg/m³ or less, as specified in CDPH Standard Method v1.2.
- (B) The sum of all measured normal aldehydes from formaldehyde through nonanal, plus benzaldehyde, individually calibrated to a compound specific standard. Heptanal through nonanal are measured via TD/GC/MS analysis and the remaining aldehydes are measured using HPLC/UV analysis.
- (C) Particle emission requirement only applicable to HVAC Duct Products with exposed surface area in air streams (a forced air test with specific test method) and for wood finishing (sanding) systems.
- (D) Based on the CA Prop 65 Maximum Allowable Dose Level for inhalation of 3,200 µg/day and an inhalation rate of 20 m³/day
- (E) Allowable levels for chemicals not listed are derived from the lower of 1/2 the California Office of Environmental Health Hazard Assessment (OEHHA) Chronic Reference Exposure Level (CREL) as required per the CDPH/EHLB/Standard Method v1.2 and BIFMA level credit 7.6.2 and 1/100th of the Threshold Limit Value (TLV) industrial work place standard (Reference: American Conference of Government Industrial Hygienists, 6500 Glenway, Building D-7, and Cincinnati, OH 45211-4438).

